

VT490 / Humidity and temperature sensor

Documentation page: <https://vutlan.atlassian.net/wiki/spaces/DEN/pages/35127341/VT490+Humidity+and+temperature+sensor>

Product page: <https://vutlan.com/can-sensors/28-vt490-dual-humidity-and-temperature-sensor.html>



Function and purpose


High-quality humidity and temperature sensor with reliable price.

Technical specifications

Communications	Description
Sensor type	CAN digital sensor
Inputs/Outputs	x2 RJ11 6P4C ports
Daisy chain	Yes, the daisy chain is possible for all CAN sensors.
Max. distance from the monitoring unit:	225m
LED indicators:	Red / Green (RUN/ERR)

Accuracy	
T accuracy:	±0.4 °C (max), -10 to 85 °C
RH accuracy:	± 3% RH (max), 0-80% RH
Resolution	0,1 °C
Environmental	
Working temperature range:	-40 to +100 °C
Humidity operating range:	0 to 95% RH
Power Requirement	
Power input:	12V DC, 1A
Current consumption:	1 Watt
Mechanics	
Dimensions:	68x47x26 mm
Packaging weight:	160 g
Mounting options:	Desktop, Wall mount
General	
Manufactured in:	Slovak Republic, European Union
Manufactured by:	Vutlan s.r.o.
HS code:	9025 11 800
Warranty:	90 days

Physical description



1. LEDs: **"RUN" (green)** - indicates that the appliance is correctly connected to the main module, **"ERR" (red)** - indicates an error, the appliance lost connection to the main module.

2. **"Humidity & temperature sensor"**

3. **"TR"** - This switch should be turned to **"ON" (down)** position if the sensor is the last sensor in the CAN chain.

Example 1: We have 1 CAN sensor connected to the main module VT8101 on the CAN bus. In this case, this sensor is the only one and the last one in the CAN chain, and its 2nd "TR" switch should be in the "ON" (**down**) position.

Example 2: We have 5 sensors or modules connected to the main module via the CAN bus. The sensor is *not the last sensor* in a chain, for example, it is located in the middle of the chain. In this case, the "TR" switch must be in the "OFF" (**up**) position.

Example 2: We have 5 sensors or modules connected to the main module via the CAN bus. The sensor is *the last sensor* in a chain. The "TR" switch must be in the "ON" (**down**) position.


4. "CAN" - two equivalent digital connectors RJ11 6P4C for the connection to the master module, CAN sensors, or CAN extensions on a CAN bus, with auto-sensing.

Drawings



VT490 v14.2 DWGs.pdf

Example connection



Connecting CAN devices


CAN sensors and CAN units connection

1. Connect CAN devices to any port CAN1 or CAN2 on the monitoring system using a cable supplied. CAN sensors can also be connected to the port of another CAN sensor or CAN unit which is connected to the CAN bus. Determination of the devices and their connection is done through a web interface.

You can connect up to a maximum of x12 CAN sensors and CAN devices together on one CAN bus (approximately)!

If you want to connect more than x12 CAN units, you need to use [CAN-12V-1A / CAN Power Supply](#)

2. The TR should be "ON" for the last sensor on each bus "CAN 1" and "CAN 2". See section "TR" below.



This procedure applies to the following sensors, which are supported by the appliance and are connected to the CAN ports:

CAN sensors, modules:

- [VT408 / Extension unit](#)
- [VT430 / Rack control unit](#)
- [VT440 / Dry contacts unit](#)
- [VT460 / Smoke, humidity, and temperature...](#)
- [VT470 / PIR, vibration and temperature sensor](#)
- [VT490 / Humidity and temperature sensor](#)
- and [other...](#)

CAN extension unit:


- [VT408 / Extension unit](#)

Read more about [Setting up CAN sensors](#).

Used cable and limit line length

The maximum length of the CAN line in Vutlan monitoring systems is **225 m** due to limitations on the ohmic resistance of cables with RJ12 connectors.

It is advisable to use two or three pairs of cables such as UTP Cat3.5.6 with 24AWG with a copper core. It is possible to use a 4-wire or 6-wire TRONIC or UTP CCA cable, but the maximum CAN line length will be reduced.




TR termination switch

The last sensor TR switch on a CAN chain must always be terminated, (switched ON). Sensors on a CAN bus that is in the middle should have TR switched OFF.


FR should always be OFF.

TR switch is always the DP switch nearest to the CAN bus.

Only older Vutlan models have an FR switch.



pic.1.1: FR is OFF, TR is ON.



pic.1.2: FR is OFF, TR is OFF.

Adding CAN modules and sensors

To connect the CAN module or CAN sensor to the CAN bus of the system, go to the interface >> CAN configuration panel >> Select the CAN1 or CAN2 tab (select the connected physical CAN1 or CAN2 port on the master module).

Click the "Configure" button and wait. The system will start CAN bus polling, soon it will display the data lines and write "Done!". The modules and sensors connected to the CAN input will appear in a tab in the list. Click the Apply button and then Restart.

The green LED "**CAN status**" of the device will light up.

VUTLAN

Monitoring & Control Systems

operator

Overall stats

System tree

Outlets

Dry outputs

Dry inputs

Event log

Logic schemes

Cameras

Map

Users

Access control

CAN configuration

Graphs

Reset smoke detectors

Preferences

System menu

CAN configuration

CAN 1

Network name

can0

State

up

Mode

normal

Last update time

2020-05-13 8-42-42 PM

Product code	Description
VT440 (6)	32/64 dry contacts
VT460 (7)	Smoke, temperature, humidity
VT430 (10)	PIR sensor, 2 dry, humidity, temperature
VT490 (8)	Temperature, humidity
VT490 (8)	Temperature, humidity
VT490 (8)	Temperature, humidity
VT430 (10)	PIR sensor, 2 dry, humidity, temperature
VT430 (10)	PIR sensor, 2 dry, humidity, temperature
VT430 (10)	PIR sensor, 2 dry, humidity, temperature
VT430 (10)	PIR sensor, 2 dry, humidity, temperature


Refresh

Save

Configure

Restart

Go to panel "System Tree" to see the new devices or new sensors. The article numbers for CAN devices are VT4xx. If they do not appear, wait, or refresh.



If after clicking the "Configure" button the poll is reset to the phrase "Update", then the line is not connected or the terminators on the bus are not agreed. It is necessary to check and change the condition of the **TR terminators** (See "TR termination switch" section above) on the modules or check and possibly change the **connection cables**.

Warning: If the bus is not matched, that is, there are bad contacts or bad cables, or the TR terminator is in the "ON" position on the intermediate devices (position 2 on the VT408), or the line is too short for matching on both CAN end devices, CAN on this line can work malfunctioning or the line as a whole may not function. (CAN line failure may occur if the parallel CR switch is in state 1, must be in OFF).

LEDs

CAN sensors have LEDs that indicate the following states:

- Red continuous light, green flickers - no communication with the master module
- Red continuous light, green is off - there is a connection with the master unit, but is not included in the monitoring system (not configured)
- Red is off, Green continuously light - work as part of a monitoring system
- All LEDs are off: no power or sensor is defective.

Maximum cable length test

Model	Description	50m	100m	150m	200m
VT408	Sensor extension unit		ok		
VT408DIN			ok		
VT430	Rack control unit		ok		
VT440	Dry contacts unit		ok		
VT460	Smoke, humidity, temperature		ok		
VT490 / VT490i	Dual humidity and temperature sensor / Pressure, humidity & temperature sensor		ok		

see also:

- [VT408 / Extension unit](#)
- [VT408DIN / Extension unit](#)
- [VT430 / Rack control unit](#)
- [VT440 / Dry contacts unit](#)
- [VT460 / Smoke, humidity, temperature sensor](#)
- [VT490 / Humidity and temperature sensor](#)
- [VT490i / Pressure, humidity and temperature sensor](#)
- [CAN-12V-1A / CAN Power Supply](#)

CAN configuration

Enable CAN

Inside the web interface of the system go to >> Preferences menu >> Network tab >> Enable CAN >> Save >> Save settings to flash (An icon in the top right corner of the web interface)

Configuration

CAN bus is used for connection of CAN sensors and CAN modules. The device has two independent CAN nodes: CAN1 and CAN2.

Before using CAN sensor module, CAN bus must be configured in order to operate with this CAN sensor module. To configure CAN bus go to "Main menu" >> "CAN" menu, which in turn has two identical tabs - one for each node.

CAN configuration

username: guest

CAN 1

CAN 2

Network name

can0

State

up

Mode

normal

Last update time

2015-02-04 9:26:29 AM

Product code	Description
sc470 (1)	Motion, vibration, temperature
sc408 (4)	8 analog (with auto detecting) sensors

Refresh

Save

Configure

Restart

Each station tab contains current information on the status of the node and a list of CAN sensor modules connected to this node.

The following operations can be carried out on CAN bus node:

- Refresh - updates the current information on the status of the node;
- Configure - launches configuration process of the nodes for CAN sensor modules connected to it, the old configuration is lost
- Save - saves the list of CAN sensor modules in flash memory;
- Restart - restarts the CAN bus node.

To delete a CAN sensor module, click on a desired module. A modal window will pop up. Press "Delete" and confirm.

CAN Device

×

Node ID

58

Vendor ID

781

Product code

sc408 (4)

Revision

0.03

Serial number

19

State

operational

Description

8 analog (with auto detecting) sensors

Delete

Cancel

To set up a CAN bus node for operation with the CAN sensor module, connect CAN module to CAN network and run corresponding configuration procedure in the web-interface using command "Configure". The configuration process is displayed at the bottom of the tab and lasts approx. 2 minutes. Detected modules will be added to the list of modules during the configuration process. After completing configuration the node returns to its normal operation. Sensors of detected CAN modules are added to the tree of elements.





The names of the sensors are automatically set in the form {module name}-{serial number}-{type of sensor} and can be edited.

If you need to remove CAN sensor module from the configuration list use command Delete, then use command "Save" to apply the changes you made and restart the node using command Restart.

- [Configuring VT408](#)

Packaging includes

Make sure that the contents of the delivery meet the following configuration. Report a missing or damaged component to your supplier. If damage occurred during transportation, contact the appropriate delivery service.

	Package content	Description
1		x1 pc, Sensor
2		x1 pc, RJ11 6P4C 2m phone cable
3		x2 pcs, Self-adhesive sticker
4		x2 pcs, Screws M3.5 10mm

5		x2 pcs, Screws M3,5 13,5mm
6		x2 pcs, Nuts M3.5
7		x2 pcs, M3.5 washers

API: managing system elements by 3rd party Software

Vutlan has an open API. Read more at:

<https://vutlan.atlassian.net/wiki/spaces/API/pages/335740995/Managing+system+elements>

Copyright:

Vutlan s.r.o.

Remote Infrastructure Monitoring and Control

43 ul.Svornosti, 821 06 Bratislava,

Slovak Republic, E.U.

www.vutlan.com